

Mach<sup>®</sup> Tripoint<sup>®</sup>

KOHLER, FAUCETS Touchless urinal flushometer, HES-powered, 1.0 gpf

## K-10UH00K30

#### Features

- Activation distance is factory-set
- Chloramine and chlorine resistance on all rubber components exposed to waterway
- Engineered for optimal performance with KOHLER® commercial fixtures
- 125-micron filter protects internal components
- High back pressure vacuum breaker
- Locking stop cap provides protection against vandalism
- No external flush volume adjustment ensures water conservation
- 24-hour automatic sentinel flush keeps trapway fresh
- Mechanical override enables flushometer to be used manually even during a power outage
- Powered by a 30 year/875,000 cycle hybrid energy cell, based on 72 uses per day
- Intended for urinal installations with 1-1/4" top spud coupling connection

#### Material

Brass construction with durable Polished Chrome finish

#### Technology

- Electronic infrared sensor with Tripoint® technology for accurate activation
- Patented piston technology for superior flush volume accuracy

#### **Recommended Products/Accessories**

K-23723 Faucet cleaner 1421939 1509698





## **Codes/Standards**

ASME A112.18.1/CSA B125.1 ASSE 1037/ASME A112.1037/CSA B125.37 ADA ICC/ANSI A117.1 CSA B651 OBC

#### **KOHLER® One-Year Limited** Warranty

See website for detailed warranty information.

## Available Colors/Finishes

Color tiles intended for reference only.

**Color Code Description** 




CP **Polished Chrome** 



# Mach® Tripoint®



Touchless urinal flushometer, HES-powered, 1.0 gpf K-10UH00K30



## **Technical Information**

All product dimensions are nominal. Power source: Hybrid Energy Cell, not included

#### **Pressure/fixture Supply Requirements**

Fixture pressure max (static):	80 psi (551.6 kPa)
Fixture pressure min (static):	25 psi (172.4 kPa)
Min flowing pressure:	25 psi (172.4 kPa)
Min flow rate:	25 gpm (94.6 lpm)

#### Notes

Install this product according to the installation instructions.

ADA, OBC, CSA B651 compliant when installed to the specific requirements of these regulations.

